



Kern County Fire Department

Office of the Fire Marshal

2820 M St. ~ Bakersfield, CA 93301

Phone: (661) 391-3310 ~ Fax: (661) 636-0466/67

www.kerncountyfire.org

fireprevention@kerncountyfire.org

**Kern County Fire Department
Report, December 2022**

Location:

3000 COLLEGE HEIGHTS BLVD, RIDGECREST,
Kern, CA, 93555

Inspection Date:

December 7, 2022 at 12:19:12
PM

Record Type:

Fire/Operating/T19/NA

Record ID:

T19-015234

Inspection Type:

Reinspection

Inspector:

Simon Arrieta

Result:

Granted

Comments:

Cerro Coso College

Emergency Procedures for Schools:

Each school shall prepare procedures to be followed in case of fire or other emergency & shall post in each classroom or assembly area a plan showing paths of travel to evacuate & an alternate route. Classrooms shall also have posted instructions to be followed by the teacher. T19 3.13(a)(2)

Exit aisles, hallways, and stairways must be clear of obstructions. Minimum 36" of travel width. CFC Sec 1020.2 in room O and exit door in classroom is blocked and kids play equipment blocking exit.

Occupant load sign shall be posted in a conspicuous place, near the main exit or exit access doorway from the room or space. CFC Sec 1004.9 Community room

Inspector

Contractor